



Kenya Power

Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our Ref: KP1/9A.3/OT/07/19-20/li

19th September 2019

TO ALL TENDERERS

RE: ADDENDUM - TENDER NO. KP1/9A.3/OT/07/19-20 FOR SUPPLY OF STREET LIGHTING MATERIALS

Please refer to the above Tender. We make the following clarifications and amendments to the Principal Tender Document (hereinafter abbreviated as the PTD) for Supply of Street Lighting Materials.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. TECHNICAL CLARIFICATION ON TENDER NO. KP1/9A.3/OT/07/19-20 FOR SUPPLY OF STREET LIGHTING MATERIALS

Reference is made to your emails, seeking clarification on the above Tender. The clarifications are made as below;

No.	Bidder Question	KPLC Clarification
1.	Can we view the LED samples at KPLC stores?	The LED Lanterns 80&100W have never been bought by KPLC before please follow the given technical specifications to the latter
2.	Clause 4.3.2.16 and Clause 4.3.8.9 of the specifications mentions CCT as 4000K and while GTP mentions > 5000K	The value should be >4000K

NB:

For all new responsive manufacturers, due diligence SHALL be mandatory.


3. TENDER CLOSING DATE

Kindly note the Tender Closing Date remains the same.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED

A handwritten signature in blue ink, consisting of several overlapping loops and a long horizontal stroke extending to the left.

JANE NDINYA

AG. SUPPLY CHAIN MANAGER, PROCUREMENT