



*The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000-Telegrams 'ELECTRIC'
Fax No. 254-02-3514485
StimaPlaza, Kolobot Road*

Our Ref. IFB No. KP1/12A-2/AFD/A38MK/skm

IFB No. KP1/12A-2/AFD/A38

25th February, 2015

M/s

Dear Sir/ Madam

**RE: ADDENDUM NO1.TO THE TENDER. IFB No. KP1/12A-2/AFD/A38.TENDER FOR
SUPPLY OF COMPACT FLOURESCENT LAMPS**

Following a clarification from our prospective bidders, we make the following clarifications and amendments to the principal tender document issued in January, 2015.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document

2. CLARIFICATION ON QUERIES RAISED BY BIDDERS

NO.	Question	Answer
1.	Page 1 of tender document gives following tender reference: ICB KP1/12A-2/AFD/A38. Page 3 however gives IFB KP1/12A-2/AFD as reference. Kindly clarify what reference to use.	The reference to quote is IFB No. KP1/12A-2/AFD/A38

NO.	Question	Answer
2.	<p>Page 77 of the Technical Specifications, Item 28. Switching Cycles reads <0.3 sec (rather than > 0.3 sec).</p> <p>Please clarify.</p>	<p>Page 77 of the Technical Specifications, Item 28. Switching Cycles should read >0.3 sec (rather than < 0.3 sec) as per EU Directive 244/2009 stage 5 .The appropriate test reports to be provided with the bid.</p>

4. DEADLINE FOR SUBMISSION OF TENDER

The tender closing date remains the same as indicated in the invitation for bids i.e. **17th March 2015**. All the other terms and conditions remain as per the tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.



ENG. JOHN OMBUI
GENERAL MANAGER, SUPPLY CHAIN