



Kenya Power

Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

12th June, 2014

M/s

Dear Sir/Madam,

ADDENDUM TO TENDER NO.KP1/5DA/PT/15/13-14

**TENDER FOR DESIGN, SUPPLY INSTALLATION, TESTING &
COMMISSIONING OF IP SURVEILLANCE CCTV SYSTEM FOR
ELECTRICITY HOUSE MOMBASA, NAKURU AND MBARAKI TENDER
NO. KP1/5DA/PT/15/13-14**

The following amendments are made to the specified provisions of the Public Tender document for the Supply, Installation, and Testing & Commissioning IP Surveillance CCTV system for Electricity house Mombasa, Nakuru and Mbaraki.

- 1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**
Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.
The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.
- 1. BILL OF QUANTITY AND SCHEDULE OF REQUIREMENT**
Bill of quantity and schedule of requirement have been amended as in the minutes attached to this addendum to capture the additional CCTV cameras and Access control units. (See attached amended tender document Page 36-43 and the Pre-bid minutes).
- 2. DRAWINGS**
Available drawings of the sites are attached. (Appendix D1, Appendix D2 AND Appendix D3) as per the minutes.
- 3. LIST AND BRAND OF EXISTING CAMERAS**
Included in the amended tender document SECTION X (Technical specifications-Item 2 Existing Equipment-additional information on existing cameras on Page 85).
- 4. DEADLINE FOR SUBMISSION OF TENDER**
The tender closing date shall be Monday, 23rd June 2014 at 10.00 a.m. The procuring entity will open the bids thereafter on the same day in the auditorium Stima Plaza.
- 5. BIDDER'S REQUEST FOR CLARIFICATION**

A bidder had raised the following issues to which response is given as follows:-

1. The camera must use four 2 megapixel CMOS image sensors Bayer mosaic RGB filter 1/2|| optical format – I can meet this with an alternative fish eye.

Response: Procurement Act allows alternative offers as long as they meet the minimum technical Specifications. However, our tender requires that you submit only one bid.

2. The use of the term “must” is restrictive and does not give a general – minimum requirement.

**Response:
Please be specific the items where the term “Must” has been used so that we can respond accordingly.**

3. There are other technologies like MOS sensors which are better than CMOS - you specified CMOS.

**Response:
The specifications given are minimum and any superior offer is accepted.**

4. This specs provided are for Arecont vision – however much I try I cannot much it 100%, and there is only one distributor in Kenya for the same.

**Response:
Kindly offer a bid that meets the minimum technical specifications or a better alternative.**

5. There is a technology to compensate for higher megapixel specified i.e 8,12mpx and achieve same HD clarity

**Response:
Kindly offer a bid that meets the minimum technical specifications or a better alternative.**

6. Built in IR illuminator having wide angle coverage to compensate for “removable IR Cut Filter”

**Response:
Please clarify the query. Are you proposing removable IR as an alternative? If yes, alternatives are accepted as long as they meet minimum technical specifications.**

All the other terms and conditions remain as per the tender document.

Yours faithfully,
For: KENYA POWER & LIGHTING COMPANY LIMITED.


A.N. GATUKUI
PROCUREMENT MANAGER.