



Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our Ref: KP1/9AA-3/PT/29/14-15

3rd December 2014

M/s
.....

Dear Sirs,

ADDENDUM NO. 1 TO THE THREE YEAR FRAMEWORK TENDER NO. KP1/9AA-3/PT/29/14-15 FOR SUPPLY OF PREPAID METERS

The following amendments are made to the specified provisions of the Tender document for Supply of prepaid meters dated November 2014.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. CLARIFICATION ON QUERIES

Query	Clarification
UIU shall be powered by means of lithium battery for three phase prepaid meter using RF as a medium of communication between	A standard alkaline replaceable battery shall be acceptable
Terminal holes for single phase prepaid meter using cable and radio frequency	The size should be able to accommodate at least 150mm length of stripped cable for firm

respectively	termination
Degree of protection for single phase prepaid meter using radio frequency	MCU enclosure in Appendix A of the tender specification rating should be IP54
Degree of protection for three phase	For all the UIU shall conform to the degree of protection IP54 as given in IEC 529
UIU LCD display	UIU display shall have 7 numerical characters
Din rail mounting type meter	It is mandatory to have Din rail mounting meters
Load switch for three phase prepaid meter using radio frequency	The load switch shall be inbuilt in the meter
MCU dimensions for single phase prepaid meter using PLC as a medium of communication between MCU and UIU	The MCU dimensions shall not exceed: Height = 170 mm; Width = 60 mm; and Depth = 130 mm; and meter base shall be on the width side where the Din rail mount shall be located.

3. DEADLINE FOR SUBMISSION OF TENDER

The closing date for the tender remains **Wednesday 14th January 2015 at 10.00 a.m.** Tenders shall be opened immediately thereafter in the Auditorium located at Stima Plaza, Kolobot Road, Nairobi.

All the other terms and conditions remain as per the tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.



Eng. JOHN OMBUI
GENERAL MANAGER, SUPPLY CHAIN