



Kenya Power

*Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
StimaPlaza, Kolobot Road
Nairobi, Kenya*

Our Ref: KP1/9A.3/OT/14/18-19/JN/hm

17th June 2019

TO:

ALL PROSPECTIVE BIDDERS

RE: ADDENDUM NO.4 TO THE TENDER NO. KP1/9A.3/OT/14/18-19 FOR FOR THE SUPPLY OF 11KV & 33KV AUTORECLOSERS.

Please refer to the above tender.

We make the following amendments to the above Principal Tender Document (hereinafter abbreviated as the PTD) for the Supply and delivery of 11KV & 33LKV Autoreclosers

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATION ON TECHNICAL ISSUES ON TENDER NO. KP1/9A.3/OT/14/18-19 FOR SUPPLY OF 11KV & 33KV AUTORECLOSERS

Reference is made to the tender no. KP1/9A.3/OT/14/18-19 for supply of 11KV and 33KV Autorelosers

Kindly note the queries asked by one of the bidders and the response for KPLC.

1. We would like to know the required the **interrupting capability** for the 11KV Autoreclosers,

Response: As per clause 4.1.4 it is 12.5kA

2. The revised 11KV specs in clause 4.4 indicate the short-time withstand current as 21kA/3sec. But clause 4.1.4 is also describing short time withstand current as 12.5kA/3sec, so what is the correct rating for withstand current?

Response: As already clarified, it is 12.5KA

3. The revised 11KV specs specify two different creepage distances - 1216mm in page 31 and 372mm in page 32. What's the correct creepage distance requirement?

Response: Minimum is 372mm

4. The revised 11KV specs have 2 different laptop specification (page 35 & page 40). Please clarify

Response: specs as detailed in page 35

Please note the clarification and adhere to it.

All other terms and conditions remain the same.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED



JANE NDINYA

Ag. SUPPLY CHAIN MANAGER, PROCUREMENT