



**Kenya Power**

---

*The Kenya Power & Lighting Co. Ltd.*  
**Central Office** – P.O. Box 30099, Nairobi, Kenya  
Telephone – 254-02-3201000  
Fax No. 254-02-3201889  
Stima Plaza, Kolobot Road

Our Ref: KP1/9A.2/OT/59/NM/18-19/BN/ck

1<sup>st</sup> August, 2019

**ADDENDUM NO. 2 TO THE TENDER NO. KP1/9A.2/OT/59/NM/18-19 FOR PROVISION OF DISTRIBUTION TRANSFORMER REPAIR SERVICES.**

The following amendments are made to the specified provisions of the Tender document.

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

**2. CLARIFICATION MADE TO THE INTERESTED BIDDERS.**

The following responses are made to clarifications sought on various issues on the tender document and shall be deemed to form the addendum.

<b>ITEM</b>	<b>QUESTION</b>	<b>KPLC RESPONSE</b>
1.	The Tender Security form is missing from the forms provided in the tender,	The form has now been attached/uploaded in KPLCs E-Portal
2.	One of the tender requirements is to provide CVs of all Team Members including Team Leader as well as Academic and Professional certificates of Team Leader. For avoidance of doubt, please confirm that the title "Team Leader" in the context of the bidder/tenderer refers to the Technical person appointed by the Service Provider/Bidder as the Workshop	The Team leader will be the key staff designated as the overall lead staff for purposes of management and execution of this contract

	Production Supervisor. It might be misconstrued to mean the person overall in charge of the business unit i.e. Chief Executive Officer, General Manager or Country Manager. Clarification is required to make it clear.	
3.	When we go through the entire tender document, it is not very clear if Section XIII (Tenderer's Commentaries) and Section XIV (Methodology and Workplan) are in relation to this particular tender for Provision of Distribution Transformer Repair Services Local Firms Only as they are not referred to in the evaluation criteria. They are also missing in tender submission checklist – Please clarify if they are in reference to this particular tender and if bidders should complete these sections.	This are not applicable for this tender
4	a) Under introduction Clause 2; KPLC is described as Public company and is subject to the state Corporation Act Chapter 442 and the laws governing PPAD Act 2015 and the various regulations. The funding is 100% public funds by KPLC which gives EXCLUSIVE PREFERENCE to Citizen Firms as described in the PPAD Act 2015.	Firms registered /incorporated in Kenya are eligible to participate in the tender. Clause 86(2) of PPAD, 2015 should apply which states that; <i>citizen contractors, or those entities in which Kenyan citizens own at least fifty one per cent (51%) shares, shall be entitled to twenty percent (20%) of their total score in the evaluation, provided the entities or contractors have attained the minimum technical score.</i>
5	Eligible Tenderers Clause 3.2.1 states ' This invitation to tender is open to all Tenderers duly registered in Kenya and Authorized to carry out the business of transformer manufacturing and/or transformer repairs. As per PPAD 2015 Clause 157 (8)(a)(i), Eligibility is only for <b>CITIZEN Firms</b> as indicated. Amend to reflect Eligibility to Citizen Manufacturers/Repairers	As response for <b>No. 4</b> above
6	Clause 3.33 Preferences. It states Preferences to be used are per PPADA 2015 and PPDR 2006 together with their regulations. If so even the TITLE of the Tender is contradicting as it States LOCAL FIRMS instead of CITIZEN FIRMS	As response for <b>No. 4</b> above
7	APPENDIX TO INSTRUCTION TO TENDERS No. 1. Based on the PPAD 2015 Clarify who are eligible to tender. <b>Clarify on this requirement</b>	As response for <b>No. 4</b> above

8	Section IV-Schedule of Requirements Clause 12 requires a <b>FULL TIME QUALIFIED ENGINEER of 1-year Experience</b> . This can only be an intern. For quality production and in line with all other engineering works, an experienced Qualified Engineer is 10 years and above. Please confirm the requirements.	Status quo remains
9	With reference to the new tender document on page 53 to 56, it is not possible to manufacture or repair transformers in Aluminium winding whose rating is higher than 315 KVA i.e. 630 KVA, 1000 KVA or higher. <b>Clarify the way forward in this situation.</b>	The purpose of this clause is to make provision for all sizes. This tender is for repair of distribution transformers in their original design and not for manufacturing transformers.

### 3. TENDER CLOSING DATE

The tender will close on 13<sup>th</sup> August 2019 at 10:00 am and opened on the same day at 10.30am as had been stipulated on Addendum No. 1.

All the other terms and conditions remain as per the tender document.

Yours faithfully,

**For: KENYA POWER & LIGHTING COMPANY LIMITED.**

  
**BERNARD NGUGI**  
**GENERAL MANAGER, SUPPLY CHAIN**

