



Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our ref: KP1/9A/9A.3/OT/24/17-18

7th June, 2018

Your ref:

TO:

ALL PROSPECTIVE BIDDERS

RE: ADDENDUM NO.1 TO THE TENDER NO. KP1/9A.3/OT/24/17-18 FOR SUPPLY OF ACCESSORIES FOR ABC CABLE

Please refer to the above Tender.

Following an enquiry from a prospective bidder thereat, and, at our own initiative, we make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for supply of Accessories for ABC Cable

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this addendum shall be deemed to have been incorporated in and shall be read and constructed as part of the PTD.

2. CLARIFICATIONS

Item No.	Item	Question/Comment by bidder	KPLC Response
1.	Item 2: Clamp Dead End for Neutral Carrier ABC	Conductor size	ABC 1 x 70 + 3 x 120. These are identified in the specification.
2.	Item 5: Connector Clamp Insulation Piercing AI ABC	Drawings/Specifications missing	Specifications provided.
3.	Item 6: End Caps – ABC	Give the size of the End Caps	These are provided for in the specification for the identified cable above.

4.	Item 12: Dead End Clamp 11kv ABC	Specifications not provided	Specifications now provided
5.	Item 19: MV Sleeve Joints for supporting catenary	Specifications not provided	Specifications now provided

3. TENDER CLOSING DATE

The tender closing date remains the same i.e. 13th June 2018 at 10:00 a.m. All other terms and conditions remain as per the Principal Tender Document (PTD)

Yours faithfully,
For: THE KENYA POWER & LIGHTING CO. LTD.



DANIEL MUGA
Ag. GENERAL MANAGER, SUPPLY CHAIN