



---

*The Kenya Power & Lighting Co. Ltd.*  
*Central Office – P.O. Box 30099, Nairobi, Kenya*  
*Telephone – 254-02-3201000-Telegrams 'ELECTRIC'- [www.kenyapower.co.ke](http://www.kenyapower.co.ke)*  
*Fax No. 254-02-3514485*  
*Stima Plaza, Kolobot Road*

**Our Ref. KP1/6D.4/.PT/1/17/HK**

**14<sup>th</sup> July, 2017**

Dear Sir/ Madam

**CLARIFICATION NO.3 - TENDER NO. KP1/6D.4/.PT/1/17 FOR PROCUREMENT OF PLANT SUPPLY, INSTALLATION AND COMMISSIONING OF 550KW SOLAR PLANT – KENYA ELECTRICITY EXPANSION PROJECT (KEEP)**

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT.**

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

**2. CLARIFICATIONS TO TENDER**

The following responses are made to clarifications sought on various issues in the Tender document for Procurement of plant supply, installation and commissioning of 550kw solar plant – Kenya Electricity expansion project (KEEP) and shall be deemed to form the addendum.

| Item | Query by Bidders  | KPLC Responses                 |
|------|---|--------------------------------|
| 1.   | Clarification No. 45 on clarification No 2 states that the Bid Form from page 49 to 52 should be filled to get the breakdown of prices for the bid<br><br>Whereas | The Bid forms should be filled |

| Item | Query by Bidders  | KPLC Responses  |
|------|---|---|
|      | <p>Clarification No. 13 of the same states that the Tables A, B and C located in Appendix to Bid should not be included.</p> <p><b>Query;</b> This is a contradiction. <b>Kindly clarify</b></p>  |   |
| 2.   | <p>Clarification No.58 on addendum No. 1. indicates that we must submit a best as possible solution.</p> <p>Whereas clarification No. 39 on addendum no. 2 indicates that we have to meet the specifications as a minimum.</p> <p><b>Query;</b> As far as I know it's not possible to get 30-year performance on framed modules.</p>  | <p>Response: There is no contradiction between 58 and 39 of the answers to the queries. The specifications is considered as the best solution.</p> <p>Bidders shall be required to specify in their offer the warranty period for the framed modules.</p> |
| 3.   | <p>SPECIFICATION FOR STEP – UP TRANSFORMER 0.415/11Kv and 0.415/33kv (630KVA &amp; 1000KVA)<br/>DESIGN AND CONSTRUCTION</p> <p>It mentions 33kv transformer, which is not stipulated in the original tender documents, so what does this mean with a 33-kV transformer? to upgrade the grid to be 33KV? should we separately quote two prices of transformer for 11KV and 33KV?</p> | <p>Bidders are advised to ignore the 33kV because it is not in our requirements. It is 11kV that is required.</p>   |

All other terms and conditions remains as per the tender document.

Yours faithfully,

**For: KENYA POWER & LIGHTING COMPANY LIMITED.**

  
**BERNARD NGUGI,**  
**GENERAL MANAGER., SUPPLY CHAIN**