



Kenya Power

*Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
StimaPlaza, Kolobot Road
Nairobi, Kenya*

Our Ref: KP1/9AA-3/PT/22/15-16/mm

7th September, 2015

M/s -----

RE: ADDENDUM NO. 1 TO THE TENDER NO. KP1/9AA-3/PT/22/15-16 FOR SUPPLY OF SUPPLY OF MINIATURE CIRCUIT BREAKERS (MCBs)

We make the following clarifications and amendments to the above Principal Tender Document (*hereinafter abbreviated as the PTD*) for the Supply of Miniature Circuit Breakers (MCBs) dated August 2015.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATIONS HAVE BEEN SOUGHT AS FOLLOWS:

Question 1:

About the MINIATURE CIRCUIT BREAKERS (MCBs) (1P+1N) 63A 230/400V 50Hz (1 PHASE- 117,000 pcs.) ,usually we have two types of MCBS, one is 2Poles MCB(1P+N), this type have range of 63A, Another type is only 1Pole(DPN) , usually we say 1 Phase.but the max current is only 32A. So I don't know which type specifically required.

Answer:

Refer to specifications clause – 4.2.3- single phase MCBs

Question 2:

Regarding the specification on housing material for the MCB's, please clarify Will housing material made from NYLON be considered as '*material of similar properties*' to the requested Polybutylene Terephthalate (PBT)

Answer:

No – as there various grades of Nylon.

**3. AMENDMENT TO SECTION XVIII TECHNICAL SPECIFICATIONS
SPECIFICATIONS FOR 3 PHASE MCBS**

Clause 4.2.11 to read:

The MCBs shall operate under curve D.

Clause 4.2.12 deleted

4.2.12 The MCB shall have an auxiliary contact that fits either at the bottom of the terminal of the MCB or on the side of the MCB.

4. CLOSING DATE

The closing has been changed from Thursday 10th September, 2015 to Thursday 1st October , 2015.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED


BERNARD NGUGI
AG. GENERAL MANAGER SUPPLY CHAIN.