



Kenya Power

*Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
StimaPlaza, Kolobot Road
Nairobi, Kenya*

Our ref: - KP1/9A.3/OT/008/24-25/Add1/JN/bkk

11th December 2024

Your ref:

TO: ALL PROSPECTIVE BIDDERS

RE: ADDENDUM NO. 1: TENDER NO. KP1/9A.3/OT/08/24-25 FOR SUPPLY OF 220KV 500MM CU S/C UNDERGROUND CABLE SEALING ENDS.

Please refer to the above Tender.

We make the following amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*)

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principle tender Document shall continue to be in full force and effect. The provisions of this addendum shall be deemed to have been incorporated in and shall be read and constructed as part of the Principle tender Document.

2. RESPONSE TO CLARIFICATIONS AS SOUGHT BY VARIOUS BIDDERS

The following is KPLC response to the clarification sought by the bidder.

No	Clarifications sought by bidders	KPLC response
1	The documents you provided it is not clear what type of terminations are required. Please confirm, if Outdoor terminations or GIS terminations are required for this tender.	The terminations required are outdoor.

3. TENDER CLOSING DATE.

The tender closing date shall remain **18th December 2024 at 10.00am**

All other terms and condition remains as per the tender document.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC

DR JOHN NGENO, OGW

GENERAL MANAGER, SUPPLY CHAIN AND LOGISTICS