



Kenya Power

Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
StimaPlaza, Kolobot Road
Nairobi, Kenya

Our ref: - KP1/9A.3/OT/008/24-25/Add2/JN/bkk

13th December 2024

Your ref:

TO: ALL PROSPECTIVE BIDDERS

RE: ADDENDUM NO. 2: TENDER NO. KP1/9A.3/OT/08/24-25 FOR SUPPLY OF 220KV 500MM CU S/C UNDERGROUND CABLE SEALING ENDS.

Please refer to the above Tender.

We make the following amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*)

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principle tender Document shall continue to be in full force and effect. The provisions of this addendum shall be deemed to have been incorporated in and shall be read and constructed as part of the Principle tender Document.

2. RESPONSE TO CLARIFICATIONS AS SOUGHT BY VARIOUS BIDDERS

The following is KPLC response to the clarification sought by the bidder.

No	Clarifications sought by bidders	KPLC Response
1	Please clarify whether the tender is open for local bidders or local manufacturers. On the TDS (ITT 3.6), it indicates it's open to local bidders. However, on the price schedule, it says LOCAL MANUFACTURERS.	These sealing ends are not manufactured locally. But the manufacturers can have local agents as bidders. (So the bidders if local need to have their bid price aligned with the Manufacturer's and have the manufacturer's authorization letter)
2	Please clarify the correct parameters on the Capacity Declaration Form.	See the amended capacity declaration form attached herewith as APPENDIX 1
3	.As per the technical specifications (Clause 4.91.5), there are many different types of sealing ends. Please indicate the exact type of sealing end required, where it shall be used and the accessories to be included e.g type of insulators required, etc.	The insulator required is composite type which comes complete with insulating fluid, the sealing ends will be used outdoor.

3. TENDER CLOSING DATE.

The tender closing date shall remain **18th December 2024 at 10.00am** as earlier indicated.

All other terms and condition remains as per the tender document.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC

HAROUN OTIENO

AG. GENERAL MANAGER, SUPPLY CHAIN AND LOGISTICS

APPENDIX 1

TABLE 2: CAPACITY DECLARATION FORM
Form 3.1 Manufacturer's Capacity Declaration Form

No.	Capacity Detail / Requirement	KPLC Requirement	Manufacturer to indicate	Meets capacity (Yes / No)					
1	Monthly Production capacity	20 PCS							
2	Delivery Period after issuance of Purchase Order	Immediately after the issuance of LPO							
3	No. of Ready Stocks	state							
4	Valid Quality Certifications	Valid ISO 9001:2015 and Type Test Reports							
5	Manufacturing Experience (From date plant was established)	Submit at least one completion certificate from KPLC or 3 reference letters							
6	Quality Assurance Plan (QAP)	Attach QAP							
7	Previous Four (4) Completed contracts in the last four years			Attach Evidence					
	No.	Contract Name	Date	Value (Kshs)	Order Quantity	Quantity Delivered	% Delivered	Country	
Overall Criteria Score									Pass / Fail

NOTES TO TABLE 1:

1. Where the Tenderer's offer fails to satisfy any one or more of the requirements as per the Criteria in Table 1 above, that Tenderer will be declared to have failed "*Failed on Mandatory Technical Requirements.*"
2. The Tenderer shall not qualify for further evaluation.
3. Where the Tenderer's offer complies with all the requirements in Table 1 above, that offer shall proceed for further evaluation as per criteria set out in Table 2.

Tenders will proceed to the Detailed Technical Stage only if they qualify in compliance with Part II clause 2.2.1 above, and Preliminary Evaluation under Clause 29.2 of the ITT.