



Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
Stima Plaza, Kolobot Road
Nairobi, Kenya

Our Ref: KP1/9A.3/OT/10/24-25/JN/ama

03rd March 2025

TO:

ALL PROSPECTIVE BIDDERS

RE: ADDENDUM NO. III FOR TENDER NO. KP1/9A.3/OT/10/24-25 FOR PROCUREMENT OF EMERGENCY RESTORATION TOWERS AND TRANSMISSION EQUIPMENT & TOOLS

Please refer to the above tender.

We make the following amendment to the above Principal Tender Document (*Hereinafter abbreviated as the PTD*) for the Procurement of Emergency restoration Towers and Transmission Equipment & Tools.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD

2. CLARIFICATION OF TENDER NO. KP1/9A.3/OT/10/24-25 FOR PROCUREMENT OF EMERGENCY RESTORATION TOWERS & TRANSMISSION EQUIPMENT & TOOLS

The following response is made to clarification sought on issue in the Specifications and tender document, and shall be deemed to form the addendum;

No	Query	RESPONSE
1	Our manufacturer for Lot 1 Infrared Thermo-imaging Cameras recommends Windows OS which will offer maximum compatibility benefits as compared to MacOS as indicated in the specification. Do we have flexibility on this matter?	Refer to Appendix I – Laptop and Phone Specs for Mobile Electronic Devices (Laptops & Phones) in the following specification: 1) KP1-13D-4-1-TSP-09-129 2) KP1-13D-4-1-TSP-09-118 3) KP1-13D-4-1-TSP-03-014 4) KP1-6C-4-1-TSP-09-055-3
2	We kindly seek clarification on the following regarding the Tifor lifts specified in the tender documents: S/No. KPLC REQUIREMENT CLARIFICATION SOUGHT	Minimum rating for Tirfor shall be 3.2 tons

No	Query	RESPONSE
	<p>1. In the tender document SECTION V – Price Schedules, Lot 5, Line Item No. 8, It is listed therein as "Tifor lifts for 3-5 tonnes " Kindly clarify the exact capacity required between 3T and 5T, as the term "Tifor lifts for 3-5 tonnes" is ambiguous and affects pricing.</p> <p>2. In the specification document no. KP1/3CB/TSP/09/061-2 The range of Tifor Lifts is listed as 0.8, 1.0, 1.6, 2, 3.2, 5 Tonnes. Please confirm the specific capacity required, as the available standard sizes in the specifications do not indicate a "3-5 tonnes" range.</p>	
3	Our OEM requests Kenya power to clarify that S355 Galvanized steel is an acceptable equivalent material?	Equivalents of aluminium alloy
4	Our OEM requests Kenya Power to clarify that our unique hoisting tower solution is acceptable as an equivalent to the integrated rail system?	Alternative Tenders shall not be considered as per ITT 12.1 of the Tender Data Sheet (TDS)
5	Our OEM requests Kenya Power to clarify that its acceptable to have attachment points every 1.5m	The structure module shall have attachment points at a maximum of 0.5m on the tower in order to install guys, insulators, or any other accessories.
6	Our OEM requests that they provide their own software (Kelsop) along with required hardware as an equivalent to PLS-CADD Lite.	Alternative Tenders shall not be considered as per ITT 12.1 of the Tender Data Sheet (TDS)

3. TENDER SECURITY

The tender security validity period shall be considered from the Initial set closing date of **27th February 2025**.

4. CHANGE OF TENDER CLOSING DATE

The tender closing date has been extended from **06th March 2025** to **13th March 2025** at 10.00am. Thereafter the tender will be opened on the same day at 10.30am.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC



Dr. JOHN NGENO, OGW

GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS