



Kenya Power

Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
Stima Plaza, Kolobot Road
Nairobi, Kenya

Our Ref: KP1/9A.3/OT/ OT/10/24-25/JM/ri

19th March, 2025

TO: ALL BIDDERS

RE: CLARIFICATION FOR TENDER NO. KP1/9A.3/OT/10/24-25 FOR PROCUREMENT OF EMERGENCY RESTORATION TOWERS AND TRANSMISSION EQUIPMENT -

Please refer to the above tender.

We Make the Following Clarifications as requested by bidders here below:

1. CLARIFICATION OF TENDER-PROCUREMENT OF EMERGENCY RESTORATION TOWERS AND TRANSMISSION EQUIPMENT - TENDER NO. KP1/9A.3/OT/10/24-25

NO	BIDDER'S QUERY	KPLC RESPONSE
1	We are writing to request a clarification on the specification KP1-13D-4-1-TSP-09-014-Specification for Line Inspection Binoculars, in table 1 magnification 10x and the objective lens diameter of at least 30mm, whereas the power states that not less than 8x42. Increasing magnification reduces the field of view, meaning for 10 magnification the FOV will be less than what is stated in the specification (At least 362ft). Please provide a range or clarify on the way forward.	Actual magnification: 10X Angular FOV: > 6° Linear FOV @1000m: >100m
2	Kindly confirm if we need ISO 9001:2015 for the binoculars	ISO 9001:2015 NOT REQUIRED
3	We request a two-week extension to prepare thoroughly.	Tender closing date extended to 27th March 2025 as per Addendum IV

All other terms and conditions remain the same.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC

A handwritten signature in blue ink, appearing to read 'John N', is positioned above the printed name.

DR. JOHN NGENO, OGW

GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS