

*The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3201889
Stima Plaza, Kolobot Road*

Our Ref: KP1/9A.3/OT/22/24-25

27th March, 2025

TO ALL PROSPECTIVE TENDERERS

RE: ADDENDUM NO. 2 TO THE TENDER NO. KP1/9A.3/OT/22/24-25 SUPPLY OF POWER TRANSFORMERS, SPARE TAP CHANGERS AND SWITCHBOARD PANELS.

The following amendments are made to the specified provisions of the Tender document for Supply of Power Transformers, Spare Tap Changers and Switchboard Panels.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. CLARIFICATION

The following responses are made to clarifications sought on various issues on the tender document.

Query No.	Clarification sought by Bidder	KPLC Response
1	<ol style="list-style-type: none">1. In the price schedule item no: 4- MA-9 Motor drive unit kindly share the serial number2. Item no. 10 and 11: switchboard panel 11KV. Kindly share the drawing for reference	<ul style="list-style-type: none">• MA9 Motor Drive Unit s/number 139267• KPLC has no standard drawing for 11kv switchboard panel. Every Manufacturer has their own design. The clarification given earlier on design is adequate i.e the switchboard panel has 2no. Incomers, 8no Outgoing feeders, 1no Bus coupler, 1no. Raiser and 2no. VT panels

3. TENDER CLOSING DATE

The tender closing date has already been extended to 15th April 2025 at 10:00am, opening of the Tender will take place thereafter at the Auditorium, Stima Plaza on the same day at 10.30am.

All the other terms and conditions remain as per the tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.



DR. JOHN NGENO, OGW

GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS