

Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
Stima Plaza, Kolobot Road
Nairobi, Kenya

Our ref: - KP1/9A.3/OT/18/24-25/Add2/JN/bkk

10th April 2025

Your ref:

TO: ALL PROSPECTIVE BIDDERS

RE: ADDENDUM NO. 2: TENDER NO. KP1/9A.3/OT/18/24-25 FOR SUPPLY OF LOWER RATED 11KV AND 33KV CABLES (DISADVANTAGED GROUPS)

Please refer to the above Tender.

We make the following amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*)

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principle tender Document shall continue to be in full force and effect. The provisions of this addendum shall be deemed to have been incorporated in and shall be read and constructed as part of the Principle Tender Document.

2. RESPONSE TO CLARIFICATIONS AS SOUGHT BY VARIOUS BIDDERS

The following is KPLC response to the clarification sought by the bidder.

No	Clarifications sought by bidders	KPLC Response
1	<p>In the provided specifications for the 11kV and 33kV specification clause 4.2.7.2 states: The armour shall consist of a three layer of round galvanized steel wires applied helically with a left – hand lay.</p> <p>4.2.7.2 The armour shall consist of a three layer of round galvanized steel wires applied helically with a left-hand lay.</p> <p>Kindly clarify if this is the current requirement, because the referenced standards in the specifications propose to only use one layer of galvanized steel wires.</p> <p>IEC 60502-2: Power Cables with extruded insulation and their accessories for rated voltages from 1kV (Um=1.2kV) up to 30kV (Um=36kV)- Part 2: Cables for rated voltages from 6kV (Um=7.2kV) up to 30kV (Um=36kV).</p> <p>Moreover, using three layers is technically possible, but not practical because there is Risk of conductor/insulation damage from excess armor layers. Also the steel wires cannot be arranged evenly and tightly, which may cause them to bulge.</p>	One Layer is acceptable

3. TENDER CLOSING DATE.

The tender closing date has been extended from 11th April 2025 to 14th April 2025 at 11.00am.

All other terms and conditions remain as per the tender document.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC


DR. JOHN NGENO, OGW

GENERAL MANAGER, SUPPLY CHAIN AND LOGISTICS