

The Kenya Power & Lighting Co. Ltd. **Central Office** – P.O. Box 30099, Nairobi, Kenya

Telephone – 254-02-3201000

Fax No. 254-02-3201889

Stima Plaza, Kolobot Road

Our Ref: <b>KP1/9A.2/OT/040/ID/24-25/JM/at</b>		14 <sup>th</sup> April, 2025
M/s		
Dear Sir/Madam,	83	ð

ADDENDUM NO.I FOR FOR PROVISION OF CIVIL WORKS AT KINANIE 66/11KV SUBSTATION UNDER TENDER NO. KP1/9A.2/OT/040/ID/24-25

The following clarifications are made to the specified provisions of the Tender document.

## 1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

## 2. CLARIFICATIONS

NO.	BIDDERS QUERY	KPLC RESPONSE
1	Post Insulator Structure- There are 2	They are different with different
	drawings of the same written	heights each has a specific drawing number -check table in tender
	Post Insulator High Level & Post Insulator	document
	Low Level- Kindly let us	
	know if they are the same	
2	Ditto but 3.0m for 66kv NCT Structure- does this mean it is the	Adopt the 66kv SD as the NCT structure -amended in BOQ
	same as Surge Diverter	
3	Cable Sealing Ends Structure- Kindly	Drawing provided and marked as
	Provide drawing for this	cable support no 009-this information clearly on tender document
	item	

4	H & I- is the drawing for Gantry And Busbar The same? Yes similar	Check form in the tender document on summary drawings
5	High Level Busbar Switch Structure- Kindly provide drawing for this	This is the high level post insulator in the drawings provided
6	Lightening Mast & Security Light Structure- The drawing provided is only for Lightening Mast kindly provide for the Security Light	Same structure will be used for both, instruction given is okay

## 3. BILL OF QUANTITIES

Bidders are informed that a revised bill of quantities (BOQ) is attached as appendix I.

## 4. CLOSING DATE

The tender closing date remains the same as Wednesday 23<sup>rd</sup> April, 2025 at 10am.

Yours faithfully,

For: THE KENYA POWER & LIGHTING CO. PLC

DR. JOHN NGENO, OGW

**GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS**