

Our Ref: KP1/9A.2/OT/045/SS/24-25/JN/skk

Date: 28th April, 2025

Your Ref:

TO: ALL PROSPECTIVE BIDDERS

Dear Sirs/ Madams

RE: ADDENDUM NO. 7 TO TENDER NO.KP1/9A.2/OT/045/SS/24-25 PROPOSED SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF ELECTRIC FENCES FOR KEY SUBSTATIONS AND SECURITY MANAGEMENT & CONTROL SYSTEM.

Please refer to the above Tender. The following clarifications and amendments are made to the Principal Tender Document (hereinafter abbreviated as the PTD) for Proposed Supply, Installation, Testing and Commissioning of Electric Fences for Key Substations and Security Management & Control System

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated into and shall be read and construed as part of the PTD.

2. 3.2 Part II - Technical Evaluation Criteria under ITT 29.3.

3.2.1.2 Submission of Relevant Manufacturer's or Principal's Authorization

NB: The tenderer must provide a certified copy of valid Manufacturers Authorization Letter (MAF) covering all items the tenderer has tendered from the Original Equipment Manufacturer (OEM). The original MAF to be sent directly to the end User (KPLC)

Should read as below

NB: The tenderer must provide a certified copy of valid Manufacturers Authorization Letter (MAF) covering all items the tenderer has tendered from the Original Equipment Manufacturer (OEM). **The original MAF shall be uploaded while submitting the bids online and not to be sent directly to the end User).**

3. SECTION VI – SPECIFICATIONS & BILLS OF QUANTITIES. SECTION VI (A) – SCHEDULE OF REQUIREMENT

Bills of Quantities for Lot 1 Electric Fences & Intruder Alarms – Coast, Nairobi, Central Rift & Ner Region has been corrected as per the attached **Appendix III**

4. CLARIFICATIONS

No	BIDDERS CONCERN	KPLC RESPONSE
1	We request you to clarify on the specifications of the chainlink and given that the site visits were concluded two days ago, we request for a 7-day extension of the tender	Chain Link should be of the same standard as the existing one. Please refer to addendum No.4 and Addendum no. 6

2	when we went for site survey for the tender of electric fence and razor wire in the cost region, we established that the materials used before rusted as a result of the weather condition in the region. The material prescribed in the tender document will also not stand the weather, are we at liberty to quote for the material that will stand the harsh condition in the region. your quick response will be highly appreciated.	Please refer to addendum no. 4
3	A. 423M Kiboko Fence	Provide as per Appendix II with dimensions and specifications as per the existing Chain Link
	Chain Link - Required dimensions not provided, please provide	
	Treated Pole - Required dimensions not provided, please provide	Provide as per Appendix II with dimensions and specifications as per the existing Poles
	HT Wire Of 6598 Metres not enough to cover 423m perimeter @ 16 lines - Clarify	HT Quantity adjusted to 7000M. Addendum No. 7
	Indicated Energizer Box Dimensions can only fit 1 energizer yet the site has 2 energizers, clarify if number of Energizer Boxes can be equal to the number of energizers	Additional 1 no.Cabinet to be supplied. Addendum 7
	B. 922M Nairobi North Fence	Razor quantities adjusted to 922M. Addendum no. 7
	Indicated 430 metres of Razor wire are inadequate to cover 922m perimeter - Please clarify	
	Indicated Energizer Box Dimensions can only fit 1 energizer yet the site has 2 energizers, clarify if number of Energizer Boxes can be equal to the number of energizers	Additional 1 no.Cabinet to be supplied. Addendum no. 7
	C. 900M Thika Depot Fence	Additional 1 no.Cabinet to be supplied. Addendum no. 7
	1. Indicated 1Pc Energizer cannot handle 900m perimeter with 8 lines - Consider increasing to 2pcs of Energizer as well as the Energizer boxes	
	2. Indicated Energizer Box Dimensions can only fit 1 energizer yet the site has 2 energizers, clarify if number of Energizer Boxes can be equal to the number of energizers	Additional 1 no.Cabinet to be supplied. Addendum no. 7
	D. 1200M Malindi Fence	Additional 1 no.Cabinet to be supplied. Addendum no. 7
	1. Indicated Energizer Box Dimensions can only fit 1 energizer yet the site has 2 energizers, clarify if number of Energizer Boxes can be equal to the number of energizers	
	F. 1400M Voi Fence	Additional 1 no.Cabinet to be supplied. Addendum no. 7
	1. Indicated Energizer Box Dimensions can only fit 1 energizer yet the site has 2 energizers, clarify if number of Energizer Boxes can be equal to the number of energizers	
4	under clause 29.3 of the ITT. Evaluation of the relevancy of the following technical information against Tender requirements and Specifications: -	Addendum no. 4
	3.2.1.2 Submission of Relevant Manufacturer's or Principal's Authorization	

a)	LOT 1-3: MAF for Alarm Control Panel, Fence Energizer	
b)	LOT 4-MAF Genetec - Please confirm if this has to be Genetec MAF or It Can also be HIKVISION MAF in case we will be riding on HIK Central platform	

1. TENDER SECURITY

The tender security validity period shall be considered from the set tender closing date of **6th May 2024**.

All the other terms and conditions remain as per the Principal Tender Document (PTD)

Yours sincerely

FOR: **Kenya Power & Lighting Company PLC**



DR. JOHN NGENO, OGW
GENERAL, MANAGER SUPPLY CHAIN & LOGISTICS.

